

DATE March 22, 2017
TO: All Prospective Proposers
FROM: Kim Albritton
Coordinator of Business Services
RE: ITB 17-21 Preventative Maintenance for Generators

ADDENDUM 1 TO 17-21 PREVENTATIVE MAINTENANCE FOR GENERATORS

This addendum is issued as a part of the aforementioned ITB. The changes incorporated herein are an amendment to and supersede those conditions shown in the original solicitation. The Proposer shall acknowledge receipt of this addendum by signing this form and returning with their submittal. Failure to do so may subject Proposer to disqualification.

Q1. Page 26, Scope of Work item 19 calls for the emergency system to be tested with full load. Please indicate the frequency at which this full load test needs to be completed, during each inspection, once per year, twice per year. Please also indicate whether this is to be a building load test which would need to be completed after hours or a load bank test which would require the contractor to supply and install load bank test equipment during each test. Please also indicate the duration of the load test, 15 minutes, 30 minutes, 2 hours, and 4 hours.

A1. System test is to be performed per NFPA 110 with the exception that test by vendor will be quarterly not monthly. In the event vendor is not able to load test due to conflict with site [i.e. testing, event that prohibits test] vendor will provide mobile unit to perform load bank testing.

Q2. The equipment list does not provide the kW rating for each of the generators and this information is needed to determine appropriate pricing for the scope of work. The cost to complete the scope of work for a 100 kW generator will be significantly different from the cost to complete the scope of work for a 750 kW unit so the kW rating for each generator is a critical piece of information required for contractors to be able to provide pricing for this bid.

Purchasing Department
4204 Okeechobee Road
Fort Pierce, Florida 34947
Voice – (772) 429-3980 Fax – (772) 429-3999

A2. The kW rating is in each of the generator model numbers if there are specific units in question please refer to them by site name and kW rating will be provided for the unit/units in question.

****** ITB DUE DATE IS: April 6, 2017- 3:00 P.M... ******

Name (Please Print)

Company Name

Signature (Authorized Representative of Company)

Date

Failure to file a protest within the time prescribed in s. 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under chapter 120, Florida Statutes. (Note: Florida Statutes 120.57(3) and School Board Policy 7.701 contain entire procedure for filing).